



# STEAM DRIP PAN ELBOW DETAIL

SCALE: NONE

## NOTE:

- 1 KEEP LENGTH OF DISCHARGE PIPING TO A MINIMUM.
- 2 PIPE DISCHARGE PIPING THROUGH ROOF – TERMINATE 10 FEET ABOVE ROOF TO PREVENT ANY POTENTIAL PERSONNEL BURN HAZARDS.
- 3 REFER TO LANL FACILITY CONSTRUCTION SPECIFICATIONS SECTION 15520 AND 15525.

NO.	DATE	CLASS REV	REVISIONS	APP
FACILITY ENGINEERING MANUAL				
STEAM DRIP PAN ELBOW				
1/2" - 1 1/2" SIZE				
APPROVED: DISCIPLINE POC DANNY NGUYEN				DATE: 6-28-99
Los Alamos		Los Alamos National Laboratory Los Alamos, New Mexico 87545		2 OF 2
CLASSIFICATION: U		REVIEWER: DANNY NGUYEN		DATE:
REFERENCE DOCUMENT: CHAPTER 6		DRAWING NUMBER: ST6204		REV